

जिला जल परीक्षण प्रयोगशाला, लोक स्वास्थ्य यात्रिकी विभाग उपखण्ड शिवपुरी

क्रमांक 53 / जि.प्र. / लो.स्वा.यां. / उपखण्ड / शिवपुरी,

दिनांक 05/06/2026

प्रति,

Sunrise Education
Academy Pichhore
Bypass Road Khaniyadhana
Distt - Shivpuri

विषय:- पीने के पानी की जांच कराने विषयक।


संदर्भ:- आपका पत्र क्रमांक 467 दिनांक 03/06/2026

उपरोक्त विषय एवं संदर्भित पत्रानुसार आपके भेजे गये जल नमूने की जल परीक्षण रिपोर्ट आपकी ओर अवलोकनार्थ संलग्न प्रेषित है।


संलग्न:- जल परीक्षण रिपोर्ट।


Principal

Sunrise Education Academy
Khaniyadhana Shivpuri (M.P.)


सचिव

गौरीशंकर शास्त्री शिक्षा एवं समाज कल्याण
समिति गूडर तह. खनियधाना (शिवपुरी)



प्रयोगशाला प्रभारी
जिला जल परीक्षण प्रयोगशाला
लो.स्वा.यां.विभाग उपखण्ड शिवपुरी

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 53Dated: 05/06/2026It is certified that an inspection team headed by Rajeev Bhatia Lab Incharge(Name of Officers with designation) from **PUBLIC HEALTH ENGINEERING DEPARMENT SHIVPURI,****MP PHED** inspected the **SUNRISE EDUCATION ACADEMY, KHANIYADHANA, NEW PICHHORE****ROAD, NEAR BY CM RISE SCHOOL, KHANIYADHANA, DIST SHIVPURI, (M.P)** on 05/06/2026and on the basis of Water Test Report (Attached) bearing no. 53dated 05/06/2026 of **PHED Water Testing Laboratory Dist.- Shivpuri, MP (PHED Lab)**certified that the **SUNRISE EDUCATION ACADEMY, KHANIYADHANA, NEW PICHHORE ROAD,****NEAR BY CM RISE SCHOOL, KHANIYADHANA, DIST SHIVPURI, (M.P)** has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic

sanitation condition in the school building & the campus as per norms prescribed by the Central/

State/ U.T. Govt.

This certificate is valid till 04/06/2027**Signature with seal**

Name

: Rajeev Bhatia
Lab Incharge

Designation

: (प्रभारी)

Name & address of the office/Department :-

सहा जल परीक्षण प्रयोगशाला
पी.एच.ई. विभाग शिवपुरी

To,

SUNRISE EDUCATION ACADEMY, KHANIYADHANA,**NEW PICHHORE ROAD, NEAR BY CM RISE SCHOOL,****KHANIYADHANA, DIST SHIVPURI, (M.P)**

(Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies

Asymani
Principal

Sunrise Education Academy
(Kaniyadhana Shivpuri (M.P.))

शक्तिशिव
सचिव

गौरीशंकर शास्त्री शिक्षा एवं समाज कल्याण
समिति गूडर तह. खनियँधाना (शिवपुरी)


Status of Sample	Chemical /Bacteriological Test	Unique Identification No.	145/1
Sender's name	By- Sunrise Education Academy Pichhore Bypass Road, Khaniyadhana Distt. Shivpuri	Sender's letter no.	Q
Sender's address	By- Sunrise Education Academy Pichhore Bypass Road, Khaniyadhana Distt. Shivpuri	Sender's letter date	03/06/2026
		Start Date Of Analysis	04/06/2026
Quantity of Sample	2 Ltr.	Receipt No.	51
Sample Collected by	Mr. Satish Rajak	End Date Of Analysis	05/06/2026

Sample details:

S.No	Distt.	Block	Village	Location	source
1	Shivpuri	Khaniyadhana	Khaniyadhana	Sunrise Education Academy Pichhore Bypass Road, Khaniyadhana Distt. Shivpuri	T.W.

Physical/ Chemical /Bacteriological Test Report With Details of Parameters Their Test Methods, Units and Specifications as per BIS.

S. No	Characteristics	Test Method (BIS 10500:2012)	Unit	As per BIS-10500:2012 & Reaffirmed in Sep. 2018		Test Result						
				Require ment (Desirab le Limit)	Permissib le Limit in the absence of Alternate Source	Sample Numbers						
1	2	3	4	5	6	1	2	3	4	5	6	7
1	Turbidity	BIS :3025 Part 10	NTU	1	5	1.4						-
2	pH	BIS :3025 Part 11	pH scale	6.5to8.5	<6.5to9.2>	7.2						-
3	TDS	BIS :3025 Part 16		500	2000	249						-
4	Total Hardness as CaCO ₃	BIS :3025 Part 21	mg/l	200	600	212						-
5	Total Alkalinity as CaCO ₃	BIS :3025 Part 23	mg/l	200	600	93						-
6	Residual chlorine	BIS :3025 Part 26	ppm	0.2	>1.0	Nil						-
7	Chloride as Cl	BIS :3025 Part 32	mg/l	250	1000	96						-
8	Calcium as Ca ⁺⁺	BIS :3025 Part 40	mg/l	75	200	57						-
9	Magnesium as Mg	BIS :3025 Part 46	mg/l	30	100	15						-
10	Iron as F ⁺⁺	BIS :3025 Part 53	mg/l	0.3	1.0	Nil						-
11	Nitrate as No ₃	BIS :3025 Part 34	mg/l	45	45	10						-
12	Fluoride as F ⁻	BIS :3025 Part 60	mg/l	1.0	1.5	0.27						-
13	Total coliform MPN100ml	standard method1992	MPN 100ml	zero	10	0						-



Signature
Authorized Signatory



Principal
Sunrise Education Academy
Khaniyadhana Shivpuri (M.P.)



सचिव
गौरीशंकर शास्त्री शिक्षा एवं समाज कल्याण
समिति गूडर तह. खनियाना (शिवपुरी)